

TERMS AND CONDITIONS ATTACHED TO APPROVAL

3. Add 3.1.9 as follows:

3.1.9 The *Drinking Water Safety Plan* in 3.1.8 shall utilize the *Drinking Water Safety Plan* template located at <http://www.environment.alberta.ca/apps/regulateddwq/dwsp.aspx> unless otherwise authorized in writing by the Director.

4. Add 3.2.7, 3.2.8 and 3.2.9 as follow:

3.2.7 The approval holder shall construct the waterworks system upgrade (the "Water Treatment Plant Upgrade") that consists of:

- (a) an additional rapid sand filter;
- (b) UV disinfection system;
- (c) on-site sodium hypochlorite generation system; and
- (d) biologically activated carbon filtration system

in accordance with the plans and specifications submitted to the Director on April 30, 2014, unless otherwise specified in this approval.

3.2.8 The approval holder shall complete the construction of the Water Treatment Plant Upgrade before December 31, 2015.

3.2.9 The approval holder shall notify the Director upon commencement of operation of the Water Treatment Plant Upgrade.

5. Delete 4.1.1 and 4.1.1.1 and substitute the following:

4.1.1. Before the Water Treatment Plant Upgrade is completed, the approval holder shall:

- (a) operate; and
- (b) maintain

a waterworks system, which shall include all of the following:

- (i) a temporary infiltration pit in the W½ 6-20-2-W5M producing surface water,
- (ii) an infiltration gallery in the NW¼ 6-20-2-W5M producing groundwater under the direct influence of surface water,